





IMPORTANT!		
<p>OWNERS MUST MAINTAIN SUFFICIENT HEAT (MINIMUM 54°F) THROUGHOUT THE AREAS WHERE "WET" SYSTEM ARE INSTALLED TO PREVENT FREEZING OF WATER UNDER ANY FREEZE OR DRY SYSTEM PROTECTION.</p>		
<div style="border: 1px solid black; padding: 2px; display: inline-block;"> 12 in </div>	<div style="display: flex; align-items: center;">  <div style="margin-left: 10px;"> <p>INDICATES THE DISTANCE IN INCHES OR MILLIMETERS FROM THE CENTER LINE OF THE PIPE TO THE UNDERSIDE OF THE CEILING, CONCRETE SLAB OR ROOF DECK.</p> </div> </div>	<div style="display: flex; align-items: center;"> <input type="radio"/> <div style="margin-left: 5px;">HYDRAULIC REFERENCE POINT</div> </div>
<div style="border: 1px solid black; padding: 2px; display: inline-block;"> 4.0' </div>	<div style="display: flex; align-items: center;">  <div style="margin-left: 10px;"> <p>INDICATES THE DISTANCE IN FEET OR MILLIMETERS FROM THE CENTER LINE OF THE PIPE TO THE FLOOR.</p> </div> </div>	<div style="display: flex; align-items: center;"> <input type="checkbox"/> SPRINKLERS IN CENTER OF TILES NONE <input type="checkbox"/> 1 WAY <input type="checkbox"/> 2 WAYS </div>
NOTES		
<p>THIS DRAWING IS THE PROPERTY OF VIKING PIPE PROTECTION INC. AND IS INTENDED TO BE USED FOR PURPOSES OF THIS PROJECT. THE DISTRIBUTION OR REPRODUCTION IS PROHIBITED UNLESS EXPLICITLY AUTHORIZED.</p>		



1. LINES TO BE SCH.10 BLK. PIPE (GRVD. ENDS) C/W SNAPLETS FOR HEADS & DROPS, JOINED WITH GROOVED FITTINGS
2. DROPS TO BE SCH.40 BLK. PIPE WITH BLK. C.I. SCRD. FITTINGS
3. MAINS TO BE SCH.10 BLK. PIPE (GRVD. ENDS) C/W MECH-TEES FOR LINES, JOINED WITH GROOVED FITTINGS

WOOD

3/8" HANGERWIRE FOR 4" OR SMALLER PIPE

3/8" ALL THREAD ROD

SWIVELL RING

TYPICAL HANGER

NO. _____ SCALE

[illegible]