



VESSEL (A): 0705257
DATE OF INSPECTION: 2024 Jan 15
DATE OF ISSUANCE: 2024 Feb 12



Certificate of Inspection Permit

Pressure Equipment Safety Regulation Section 33

ENERGERA INC

11551 BEVINGTON ROAD

ACHESON, AB
T7X 6C1

COMPANY CODE:

DESCRIPTION: INDIRECT FIRED HEATER COILS

LOCATION: SPARE, ACHESON

MANUFACTURER: FOURSTAR RESOURCES INC

Next Inspection Due Date: 2025 Jan 15

Max. Inspection Interval: 1.00Yr

Year Built: 2024

CRN: T2002.2

Serial #: 231098 C2

Volume: 0.046 M3

Heating Surface: 4.63 M2

Surface Area:

Pressure Relief Valves

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
COIL	9377 KPA	93 C	-29 C	SV1			TO BE INSTALLED


At the time of inspection the item described on the Certificate of Inspection Permit was found to comply with the requirements set forth in the Pressure Equipment Safety Regulation and appeared suitable for operation.

Terms and Conditions:

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed of.

The owner or person in charge shall report all unsafe conditions, accidents and fires involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.

Permit issued by: PARKER, MONICA



Signature: *Monica Parker*

Pursuant to Section 44 of the Safety Codes Act, the item described in this Certificate of Inspection Permit is authorized to operate in the Province of Alberta, within the operating limits established herein, provided all terms and conditions detailed in this Permit have been satisfied.