VESSEL (A): 0705258
DATE OF INSPECTION: 2024 Jan 15
DATE OF ISSUANCE: 2024 Feb 12

the pressure equipment safety authority

Certificate of Inspection Permit

Pressure Equipment Safety Regulation Section 33

ENERGERA INC

11551 BEVINGTON ROAD

ACHESON, AB
T7X 6C1

Next Inspection Due Date: 2025 Jan 15
Max. Inspection Interval: 1.00Yr
Year Built: 2024
CRN: V6504.2
Serial #: 231098V1
Volume: 0.125 M3
Heating Surface:
Surface Area:

COMPANY CODE:
DESCRIPTION: VERTICAL SEPARATOR
LOCATION: SPARE, ACHESON
MANUFACTURER: FOURSTAR RESOURCES INC

Pressure Relief Valves

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	1965 KPA	38 C	-29 C	SV1			TO BE INSTALLED

At the time of inspection the item described on the Certificate of Inspection Permit was found to comply with the requirements set forth in the Pressure Equipment Safety Regulation and appeared suitable for operation.

Terms and Conditions:

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed of.

The owner or person in charge shall report all unsafe conditions, accidents and fires involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.

Alberta Boilers Safety Association
ABSA
Monica Parker
NB 14446 AB-422
D00006748
Safety Codes Officer

Permit issued by: PARKER, MONICA

Signature: Monica Parker

Pursuant to Section 44 of the Safety Codes Act, the item described in this Certificate of Inspection Permit is authorized to operate in the Province of Alberta, within the operating limits established herein, provided all terms and conditions detailed in this Permit have been satisfied.